



Performance Test Certificate

Issued To

KHEDR TRUST COMPANY

Intertek has tested a representative sample of
KHEDR Trust Company
Model CD-1-7-L2-Size 1 Round Ceiling Diffuser
(200mm Diameter Neck)

A Size 1 Round Ceiling Diffuser was tested
in accordance with the standard listed below and was found
to perform in a manner appropriate to the dictates of the standard.

STANDARD

ASHRAE 70-2006 Standard
“Method of Testing for Rating the Performance of Air Outlets and Inlets”

SCOPE OF TESTING

The diffuser was tested for the following performance characteristics:
"Reference Intertek Report Number 104284248CRT-002a dated March 26, 2020"

- A) Sound Power Level ((NC)
- B) Air Volume versus Static Pressure
- C) Area Factor
- D) Throw Pattern

Date: April 13, 2020

James R. Kline
Intertek
Engineer / Quality Supervisor

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.